

# Exhibit M: Fire Hydrant Flow Test Report

## HYDRANT FLOW TEST REPORT

Project Name/#/Address: Grimm's Yard/#11113/SW 128th Avenue, Tualatin



			Docu	iment Owner: John Christianse	
AFETY PLAN					
<ul> <li>Notify fire department</li> <li>Identify discharge point</li> <li>Verify downstream</li> <li>Traffic Control</li> <li>PPE</li> <li>Gauge Calibration</li> </ul>	Notes: Tualatin Hydrant Flow Test Permit #: HFT25-0317; The incorrect diffuser gauge was used during the test for the LPD-250A diffuser. 29 psi Pitot pressure would yield 852 gpm per the table on the LPD-250A diffuser, not the 920 gpm shown in the report photo.				
Date/time of test:	2/20/2020 @ 8:30 AM				
Tested by:	David Webb , Curtis Eschman, and Mitch Davenport				
Witness:	Ernie Castro of City of Tualatin, operated the hydrants for the test				
Test duration:	< 10 minutes				
LOWED HYDRANT	1F-A			1F-B	
Make:	Mueller				
Static:	66	PSI		PSI	
Pitot:	29	PSI		PSI	
Inside diameter of outlet:	2.5	Inch		Inch	
Discharge coeff:	0.9		0.9		
Observed flow:	852	GPM		GPM	
Flow method:	LPD-250A Diffus	ser with Pitot			
Ground elevation:	135	FT		FT	
Location description:	Southern-most	hydrant on SW 1	28th Avenue		
AUGE HYDRANT	1G-A				
Make:	Mueller				
Static:	64	PSI		Note: Pressure drop at gauge hydrant must be 25% to determin projected fire flow	
Residual:	61	PSI	-		
Ground Elevation:	140	FT	r.		
Location Description:	Northern-most hydrant on SW 128th Avenue				
ROJECTED FIRE FLOW					
		•	• •	cted fire flow at 20-PSI, ain is expected to delive	
Projected Flow at 20-PSI:		more than 1,00	00-gpm at 20-PS	I residual	
Projected Flow at 20-PSI: OTES/OBSERVATIONS		more than 1,00	00-gpm at 20-PS	I residual	

Dave Webb

**AKS Engineering & Forestry** 

2/25/2025 | 8 Photos



## AKS Job ID: 11113, Hyrant Flow Test

Grimm's Fuel Storage Yard



## **Flow Test Details**

A hydrant flow test was performed at AKS Job 11113 Grimm's Fuel Storage Yard on 2/20/2025. The test was performed by David Webb, Curtis Eschman, and Mitch Davenport, all of AKS. The test was assisted by Ernie Castro of City of Tualatin, who operated the hydrant valves during the test. The flow apparatus consisted of the LPD-250A diffuser with de-chlorination tablets loaded in the diffuser, connected to the flow hydrant via a section of fire hose, and directed to a downslope stormwater catch basin. The pitot gauge used during the test was incorrect, but it accurately yielded a flow psi of 30. This pressure aligns with a flow rate of 852 gpm per the flow chart of the LPD diffuser, rather than the 920 gpm shown in the report photo.



The flow hydrant, a Mueller 5 1/4.

Project: 11113 Grimms Fuel Storage Yard Date: 2/20/2025, 8:25am Creator: Mitchell Davenport

The static psi of the flow hydrant at 66 psi.



Project: 11113 Grimms Fuel Storage Yard Date: 2/20/2025, 8:32am Creator: Dave Webb

2






#### The gauge/residual hydrant, a Mueller 5 1/4.

Project: 11113 Grimms Fuel Storage Yard Date: 2/20/2025, 8:38am Creator: Curtis Eschman

The static psi of the gauge/residual hydrant at 64 psi.

Project: 11113 Grimms Fuel Storage Yard Date: 2/20/2025, 8:42am Creator: Curtis Eschman



The flow test conducted with the LPD-250A diffuser with de-chlorination tablets loaded in the diffuser chamber.


Project: 11113 Grimms Fuel Storage Yard Date: 2/20/2025, 8:48am Creator: Dave Webb

Ernie Castro of City of Tualatin operating the hydrant valves.



Project: 11113 Grimms Fuel Storage Yard Date: 2/20/2025, 8:48am Creator: Dave Webb

6



8



Residual psi of the gauge hydrant during the flow test at 61-62 psi.

Project: 11113 Grimms Fuel Storage Yard Date: 2/20/2025, 8:49am Creator: Curtis Eschman

The diffuser pitot flow gauge at 30 psi. The incorrect gauge was used, but the 30 psi translates to a flow rate of 852 gpm per the correct gauge and the chart affixed to the diffuser.

Project: 11113 Grimms Fuel Storage Yard Date: 2/20/2025, 8:53am Creator: Dave Webb